



PSB Singapore

CERTIFICATE OF CONFORMITY

Product Listing Scheme* : Class 1A

This Certificate is issued to

Associated Enterprises (S) Pte Ltd
 Blk 28 Sin Ming Drive #01-173
 Singapore 575702

FOR

Product: Fire Hosereel
 Brand: AE
 Model: 100-N, 99-N, 50-N & 55-N
 Country of Origin: Singapore
 Product Details: 19mm & 25mm diameter Swing/ Recess Fire Hosereel and
 19mm & 25mm diameter Fixed Type Fire Hosereel

which has complied with the requirements of the scheme and based on the following:

Standard(s)

BS EN 671-1 : 2001

Test Report(s)

54S023240/1/YAS
 54S023240/2/YAS
 54S064107/TSM

Vice-President (Certification Department)
 TÜV SÜD PSB

| | | | |
|-----------------|-------------------------|------------------------|-----------------|
| Certificate No: | Date of Original Issue: | Date of Last Revision: | Date of Expiry: |
| 020737 | 28/10/2002 | 28/10/2009 | 31/10/2012 |



* All products listed under Class 1A/1B must have this mark affixed / printed on them.
 Failure to comply with this requirement may result in revocation of this certificate.



This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the Product Listing Scheme. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.com.